



**NOTE:**  
 REFER E2/AS1 Fig.16 FOR FLASHING REQUIREMENTS. PROVIDE 6-8mm WIDE SEALANT JOINT AT CLADDING/SADDLE FLASHING JUNCTION.  
 50mm MIN. SET DOWN FROM FLOOR OR THRESHOLD FOR CANTILEVERED SLATTED DECKS

<b>STO POREN SYSTEM</b>	<b>STO POREN BRICK VENEER</b>	<b>PB 508</b>
	<b>CANTILEVERED SLATTED DECK</b>	<b>2014</b>

The information contained in this detail is based on our experience and testing and represents the latest information available at the date of issue. This detail is intended for use by the design professional and users of Sto products to assist in developing specific project details to be used in conjunction with a Sto Specification. We reserve the right to alter or update information at any time without prior notice & it is the responsibility of the specifier and/or the project manager to insure that they have the current Sto details and specifications.