



NOTE:
 REFER E2/AS1 Fig.16 FOR FLASHING REQUIREMENTS. PROVIDE 5mm MIN. WIDE SEALANT JOINT AT CLADDING/SADDLE FLASHING JUNCTION.

50mm MIN. SET DOWN FROM FLOOR OR THRESHOLD TO TOP OF CANTILEVERED SLATTED DECKS

SCALE 1:5

STO BRICK SYSTEM	STO BRICK SYSTEM	PB 508
	CANTILEVERED SLATTED DECK	2019