



NOTE:  
 REFER E2/AS1 FOR FLASHING REQUIREMENTS.  
 PROVIDE 6-8mm WIDE SEALANT JOINT AT CLADDING/SADDLE FLASHING JUNCTION.  
 50mm MIN. SET DOWN FROM FLOOR OR THRESHOLD FOR CANTILEVERED SLATTED DECKS

SCALE 1:5

<b>STOLITE SYSTEM</b>	<b>STOLITE CONSTRUCTION SYSTEM CANTILEVERED SLATTED DECK</b>	<b>SL 508</b>
		<b>2022</b>

The information contained on this page is based on our experience and research at the date of issue. The detail is for use by Registered Architects, Licensed Designers or Chartered Engineers to assist in developing project details using Sto Systems. Stoanz Ltd reserve the right to alter or update information at any time without prior notice and it is the responsibility of the designer, project manager or Sto contractor to ensure they have and use the current Sto details and specifications on site.