



1. DRAINED HORIZONTAL FLASHING REQUIRED TO LIMIT CONTINUOUS CAVITY CONSTRUCTION TO TWO (2) STOREYS, OR 7 METRES IN HEIGHT.
2. FLASHING SUPPLIED AND INSTALLED BY MAIN CONTRACTOR
3. IN EXTRA HIGH WIND ZONES INCREASE FLASHING COVER TO 60mm MIN. AND USE A RIGID UNDERLAY

SCALE 1:2

|                           |                                          |               |
|---------------------------|------------------------------------------|---------------|
| <b>STOLITE<br/>SYSTEM</b> | <b>STOLITE CONSTRUCTION SYSTEM</b>       | <b>SL 843</b> |
|                           | <b>HORIZONTAL JUNCTION WITH STOTHERM</b> | <b>2022</b>   |

The information contained on this page is based on our experience and research at the date of issue. The detail is for use by Registered Architects, Licensed Designers or Chartered Engineers to assist in developing project details using Sto Systems. Stoanz Ltd reserve the right to alter or update information at any time without prior notice and it is the responsibility of the designer, project manager or Sto contractor to ensure they have and use the current Sto details and specifications on site.